



LANE EDUCATION SERVICE DISTRICT

1200 Highway 99 North  
Eugene, OR 97402

541.461.8200  
541.461.8298 [Fax]

www.lesd.k12.or.us

EQUITY COMMITMENT LEADERSHIP COLLABORATION INTEGRITY

SOLICITATION ADDENDUM 2  
ITB P20002-1006-20  
WESTMORELAND HVAC UPGRADES

This Addendum modifies the Invitation to Bid (ITB) document(s) only to the extent indicated herein. All other areas not changed or otherwise modified by this Addendum shall remain in full force and effect. This Addendum is hereby made an integral part of the ITB document. Bidder must be responsive to any requirements of this Addendum as if the requirements were set forth in the ITB. Failure to do so may result in Bid rejection. See the ITB regarding requests for clarification or change and protests of this Addendum, and the deadlines for the foregoing.

The closing date **HAS CHANGED**: **The new closing date is**

**Thursday, December 17<sup>th</sup>, 2020 at 12:00 PM**

**The following changes will be made to the electrical specification 260533:**

- 3.02.B.3.f to be removed entirely.
- New item 3.02.C.5 to be added with text "Outdoor, Wet: GRC, IMC, EMT. Ensure all fittings are listed for use in wet locations and installed in compliance with manufacturer's instructions."
- Second sentence of 3.02.H to be modified to read "Homeruns for branch circuits may be combined to a maximum of six current carrying conductors in a homerun."